

# TEST CERTIFICATE

Issued to: Alfamar Electrical Systems L.L.C.  
P.O. Box 282735  
Dubai  
United Arab Emirates

For the product: Empty enclosure for low-voltage switchgear and controlgear assemblies

Trade name: Alfamar / Contactum

Type/Model: Metal enclosures with swing handle door

Ratings: IP66, IK10, indoor / outdoor  
For more details see annex

Manufactured by: Alfamar Electrical Systems L.L.C.  
P.O. Box 282735  
Dubai  
United Arab Emirates

Subject: Type tests

Requirements: IEC 62208:2011  
Clauses 9.3, 9.4, 9.6, 9.7, 9.8, 9.9, 9.11, 9.12, 9.13 and 9.14

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2190013.03-INC, dated 16 May 2017.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

m. 16 May 2017

Number: 2190013.102

DEKRA Certification B.V.

H.R.M. Barends  
Certification Manager

© Integral publication of this certificate and

reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 N.  
T +31 88 96 83000 F +31 88 96 83100 www.dekra

P.O. Box 5185, 6802 ED Arnhem, The Netherlands  
on.com Company registration 09085396