

ATTESTATION OF CONFORMITY

Number: 2130055.02A

Issued to: Alfamar Electrical Systems L.L.C.
P.O. Box 2827350
Dubai
U.A.E.

For the product: Empty enclosures

Trade name: ALFANAR / ELETRA / CONTACTUM

Type/Model: Ser. Box W/ Single glandplate SL No.1 to SL No.72

Ratings: IP65

Manufactured by: Alfamar Electrical Systems L.L.C.
Dubai Investment Park
Dubai
United Arab Emirates

Subject: Degree of protection provided by enclosure

Requirements: EN/IEC 60529:1989 + A1:1999

This Attestation is granted on account of an examination by KEMA Quality, the results of which are laid down in a confidential test report no 2130055.02-QUA/INC issued on July 14, 2010.

The examination has been carried out on single specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimens tested by KEMA Quality is not the responsibility of KEMA Quality.

Arnhem, August 10, 2010

KEMA Quality B.V.

H.R.M. Barends
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed